



Ref; Maropeng Mokhatla (SCM)  
(011) 951 - 2541

Attie Pretorius(Electricity Department)  
(011) 951-2435/2440 (082 856 1600)

**REQUEST FOR FORMAL WRITTEN PRICE QUOTATIONS**

**(Over R30 000.00 up to a transaction value of R200 000.00 VAT included)**

Kindly furnish Mogale City Local Municipality with a written quotation for the redesigning of the following services: **Q –I (E) 27/2008.**

**QUOTATIONS ARE HEREBY INVITED FOR THE SUPPLY AND DELIVERY OF BATTERY TRIPPING UNITS (INCLUDING BATTERIES).**

Closing date and time: **MONDAY 05 MAY 2008 @ 12:00**

The quotation must be submitted on the letterhead of your business and can either be faxed or delivered by hand not later than the date and time as indicated on the attached schedule to:

**Mogale City Local Municipality  
Civic Centre  
Corner Market & Commissioner Streets, Krugersdorp  
Upper Level West Wing – Reception Desk Electricity Sub-Directorate  
Tender Box 1  
Fax number: 0866548618**

---

The following conditions will apply:

- Quotation documents available from website [www.mogalecity.gov.za](http://www.mogalecity.gov.za) or from the Supply Chain Management Section (Tumi Ramatsie) at (011) 951-2541, Finance Dept, Civic Centre, Krugersdorp.
  - Price(s) quoted must be valid for at least thirty (30) days from date of your offer.
  - Price(s) quoted must be firm and must be inclusive of VAT.
  - A firm delivery period must be indicated.
  - A valid, original tax clearance certificate must be attached.
  - This quotation will be evaluated in terms of the 80/20 preference point system as prescribed in the Preferential Procurement Policy Framework Act (No 5 of 2000) and for this purpose the **enclosed forms:**
    - **MBD 2: Tax clearance certificate;**
    - **MBD 4: Declaration of interest;**
    - **MBD 6.1: HDI preference points (10);**
    - **MBD 6.3: Preference points for SMME's (5) &**
    - **MBD 6.11: Preference points to Mogale based companies (5)**must be scrutinized, completed and submitted together with your quotation.
- IF THE MBD FORMS ARE NOT COMPLETED AND SUBMITTED WITH THE QUOTATION, THE TENDERER WILL FORFEIT THE 20 POINTS ALLOCATED IN TERMS OF THESE SPECIFIC GOALS**
- The successful provider will be the one scoring the highest points.

**NB: No quotations will be considered from persons in the service of the state<sup>1</sup>**

Failure to comply with these conditions may invalidate your offer.

The person to be contacted for further information is Attie Pretorius at (011) 951-2435/2440 at the Sub-Directorate Electrical Planning Management, corner Monument and President streets, President Building, 3<sup>rd</sup> Floor, Krugersdorp.

The request for quotations is to be advertised from the **22 April 2008 to 05 May 2008 and the closing date to be 05 May 2008 at 12H00.**

Yours faithfully

## **SPECIALIST: PROCUREMENT**

---

### **PROJECT SPECIFICATIONS**

#### **QUOTATION: I(E) 27/2008: FOR THE SUPPLY AND DELIVERY OF BATTERY TRIPPING UNITS (INCLUDING BATTERIES).**

##### **1. SCOPE OF WORK**

The price must include the supplying and delivery to the Mogale City Municipal Stores, of all materials and equipment for new Tripping Battery Units for substations on the Mogale City electricity supply system.

##### **2. SPECIFICATION.**

###### **2.1 Quality**

All materials and standards shall comply with the latest editions of S.A.B.S specifications where applicable.

###### **2.2 Ratings**

Pricing must be based on the ratings of units as listed in the Pricing Schedule.

###### **2.3 Enclosure**

The cabinet suitable for wall mounting or free standing shall house both the batteries and the charging unit. It shall be of mild steel of minimum thickness of 1.6mm. Front access with hinged door panels. Corrosion resistant epoxy coating. Corrosion resistant epoxy coating natural ventilation.

###### **2.4 Charging Unit**

Input: 230 /110V 50hz single phase.2/5 Amp.

Output: 24/30 volt DC, 3/10 amp full current limit.

###### **2.5 Batteries**

24 ventilated Nickel Cadmium, 10 AH.

###### **2.6 Float Charge**

1.4 V/Cell, rate 3 Amp DC.

###### **2.7 Boost Voltage**

1.6 V/C With Indication on front panel (Automatic return to float charge)

**2.8 Load Test**

10 Ohm resistive load across battery. Manual or automatic at 12 hour intervals, maximum duration 30 seconds.

**2.9 Meters**

Analogue volt and ammeter to indicate battery voltage and charge current.

**2.10 Alarms**

Audible and visual local indication of battery failure and charger failure alarms. isolated contacts for remote monitoring of alarms.

**2.11 Colour**

Colour shall be predominantly yellow.

**3. PRICING SCHEDULE**

**3.1 Quantities**

The pricing schedule gives an indication of the Municipalities needs, but prices must remain firm for lesser or more quantities that may eventually be ordered by the Municipality.

ITEM DESCRIPTION	QUANTITY	PRICE PER ITEM	PRICE (incl. VAT)
24 V D.C. 3 Amp Battery Tripping Unit as per Specification in clause 2 above (including batteries)	10 units		

**3.2 PRICE ESCALATION**

	YES / NO	SPECIFY
Will prices be subject to any exchange rate?		
Will payment be subject to a settlement discount, if so, will it be from date of invoice or statement		

DELIVERY PERIOD FROM DATE OF RECEIPT OF OFFICIAL ORDER\_\_\_\_\_

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_